

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1525:101 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Notifier Integrated Systems, 11917 Plantside Drive, Louisville, KY 40299  
Contact: Larry Flood (203) 484-1200 Fax (203) 484-7309

**DESIGN:** Model BCI <sup>3-3</sup> Building Communicator Interface unit. Unit is intended for use with listee's separately listed model UniNet 2000 proprietary and central station receiving unit to interface between fire alarm, burglar alarm, access and energy management control equipment and a proprietary control unit through the public telephone switching network. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120/240 VAC, 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as building communication interface unit for use with listee's separately listed compatible fire alarm control units and model UniNet 2000 (CSFM Listing No. 7300-1525:100).

02-03-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager